CONTROLS

		Americans a construction of the construction o
		MHK1
	Number of Units Controllable	1
	Fan Speed Settings	5 Speeds
	Scheduling	· Separate Heat/Cool scheduling
THERMOSTATS	Optimal Start	· Set occupied time and desired set temperature · Remote controller learns when to start warm up or cool down so that space is at set temperature at start of occupied time
Š		
		· Hold function
Ш		· Temporary Scheudle Override
Į		· Reset to factory default
-	Additional Functions	
		Setting/releasing of simplified locking for remote control settings can be performed. Locking of all settings Locking of ON/OFF setting Locking of system Locking of fan setting Locking of temperature Locking of Clock/Day/Schedule
	Auto Lock Out Function	· Locking of Clock/Day/Schedule